

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-1477:117

Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Mircom Technologies Ltd, *25 Interchange Way, Vaughan, Ontario, Canada L4K 5W3
Contact: Mara Cherubin (888) 660-4655 FAX (888) 660-4113

DESIGN: Models MIX-2251, MIX-2251B, MIX-2251T, MIX-2251TB, MIX-2251TMB photoelectric smoke detector. Model MIX-2251T employs an integral supplemental heat sensor. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors when used in conjunction with listee's listed separately listed compatible fire alarm control units and bases. Each model is suitable for open areas with air velocity between 0-4000 fpm. Models MIX-2251, -2251B, -2251TB and -2251TMB are also suitable for installation inside ducts with a maximum air velocity of 4000 fpm.

XLf: 7272-1209:160

*Rev. 11-04-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**